



BACKFLOW PREVENTER SHOULD BE TESTED AND CERTIFIED AFTER INSTALLATION BY A CERTIFIED BACKFLOW PREVENTER TECHNICIAN.

WRAP ENTIRE ASSEMBLY WITH INSULATION TAPE FOR LIGHT FREEZE PROTECTION. DO NOT BLOCK DRAIN PORTS ON BACKFLOW PREVENTER,

MOST CODES ALLOW DC DEVICE TO BE INSTALLED IN A BASEMENT. MAY BE INSTALLED IN A UNDERGROUND VAULT OR BOX IN SOME AREAS, CHECK WITH LOCAL WATER COMPANY.

TEST COCKS ON RP DEVICE MUST BE ACCESSIBLE TO ALLOW CONNECTION OF TEST UNIT.

*GALV. STEEL PIPE AND FITTINGS MAY BE USED IN SOME CLIMATES. CHECK IF APPROPRIATE LOCALLY . GALV. STEEL WILL REACT WITH THE BRASS B.P. IN MANY CLIMATES RESULTING IN PREMATURE FAILURE.

Use of this drawing is at your own risk. Drawing may not be appropriate for use in all situations or conditions. Check with local authorities for specific requirements of governing codes and ordinances. By use of this drawing you agree in full to the "Terms of Use" found at <http://www.jessstryker.com/legal.htm> as if they were repeated in full here.